

DITCH INSPECTION FORM

DITCH NAME Ascher Beach Pump

TYPE 6131

OVERALL RATING

RECONST DATE 1963

LAST EXC

5 EXCELLENT

4 GOOD

0+00 STA 36 Erie

LENGTH 1622'

3 FAIR

2 POOR

1 VERY POOR

ASSESSMENT BASE 6487.51

CURRENT CONDITION AND PLAN OF ACTION

SEDIMENT	<input type="checkbox"/> GOOD CONDITION <input type="checkbox"/> BOTTOM EXCAVATION 5-10 YRS <input type="checkbox"/> NEEDS EXCAVATION SOON	
BANK STABILITY	<input type="checkbox"/> BANKS GOOD <input type="checkbox"/> BANKS STEEP LESS THAN 1.5:1 <input type="checkbox"/> RIP RAP NEEDED	
OUTLET PIPES	<input type="checkbox"/> GOOD CONDITION <input type="checkbox"/> NEED REPAIR	
VEGETATION	<input type="checkbox"/> GOOD CONTROL <input type="checkbox"/> NEEDS MOWING <input type="checkbox"/> BRUSH <input type="checkbox"/> CATTAILS <input type="checkbox"/> PHRAGMITIES	
FUTURE		

Pump maintained by Erie Twp trustees, with reimbursement for electric and other costs from the maintenance account. Project also includes some tile (storm sewer). Pump last replaced with rebuilt 6.2006. A little rough looking but well maintained. motor Capacitor replaced in 2017. Everything in good working order. Projected costs are based on past historical data. Will continue to work with Erie TWP on any future issues. No major work planned in 2019.

DATE INSPECTED: 2.12.2018

INSPECTED BY: Mike Gargac, Ron Libben