

DITCH INSPECTION FORM

DITCH NAME Zoschke Sewer & Pump

TYPE 6131

OVERALL RATING

RECONST DATE 1966

LAST EXC 1990

5 EXCELLENT

4 GOOD

0+00 STA 5 Erie

LENGTH 127'

3 FAIR

2 POOR

1 VERY POOR

ASSESSMENT BASE \$4211.70

CURRENT CONDITION AND PLAN OF ACTION

SEDIMENT	<input type="checkbox"/> GOOD CONDITION <input type="checkbox"/> BOTTOM EXCAVATION 5-10 YRS <input type="checkbox"/> NEEDS EXCAVATION SOON	
BANK STABILITY	<input type="checkbox"/> BANKS GOOD <input type="checkbox"/> BANKS STEEP LESS THAN 1.5:1 <input type="checkbox"/> RIP RAP NEEDED	
OUTLET PIPES	<input type="checkbox"/> GOOD CONDITION <input type="checkbox"/> NEED REPAIR	
VEGETATION	<input type="checkbox"/> GOOD CONTROL <input type="checkbox"/> NEEDS MOWING <input type="checkbox"/> BRUSH <input type="checkbox"/> CATTAILS <input type="checkbox"/> PHRAGMITIES	
FUTURE	2020 routine maint and elec	2021 routine maint and elec

This is a storm sewer and pump system which drains most of Lacarne. Originally it was a direct outlet into a ditch that ran to the Portage River. Due to backwater a pump system was installed in 1990 to provide an adequate outlet. This pump system is maintained by the Erie TWP Trustees with reimbursement for expenses. Currently everything is in good working order. Pump was replaced 9/2007 with a rebuilt. Cost estimate based on historical costs.

DATE INSPECTED: 2.12.2018

INSPECTED BY: Mike Gargac, Ron Libben